



NOTES:

- 1). Penetrations may be made for cable entry/exit in the top or bottom or in the non-vented portion of the sides of the enclosure. The enclosure has no knockouts or removable panels for cable entry. The factory can pre-punch holes up to 4" diameter for conduit in the location of the customer's choice - with proper advance notification.
- 2). Recommended Minimum Clearances:

Front = 36",	Top = 36"
Back = 6",	Sides = 0 to 6"

If side clearance = 0", increase back clearance by 6" for each side blocked
- 3). The front and rear access panels are identical and are of the screw on type
- 4). The standard paint color is ANSI-61 grey
- 5). The unit **MUST** be lifted from the base only
- 6). Typical detail shown, not for construction

UNLESS OTHERWISE SPECIFIED:		NAME	DATE	UTILITY SYSTEMS TECHNOLOGIES, INC	
DIMENSIONS ARE IN INCHES	DRAWN	ERS	2/16/2009	P.O. BOX 110, LATHAM, NY 12110	
TOLERANCES:	CHECKED			TITLE:	
FRACTIONAL ±	ENG APPR.			NEMA 1 Enclosure S44	
ANGULAR:	MFG APPR.				
INTERPRET GEOMETRIC TOLERANCING PER:	Q.A.				
MATERIAL	COMMENTS:			SIZE	DWG. NO.
FINISH				A	REV
DO NOT SCALE DRAWING				SCALE: 1:16	WEIGHT:
				SHEET 1 OF 1	